

Questions & Answers  
Athens Coop  
COMM #54453-9999-92  
BRRS #03-37-180959

**QUESTION:** What do you want the soil samples collected at the excavation limits analyzed for?

Answer: PVOC's plus Naphthalene

**QUESTION:** Backfilling of excavation is to be included?

Answer: Yes

**QUESTION:** Any compaction requirements for backfill if to be included?

Answer: Backfill shall be compacted in maximum 8" lifts.

**QUESTION:** What parameters are the groundwater samples to be analyzed for?

Answer: PVOC's plus Naphthalene

**QUESTION:** Are product evaluations to be conducted as part of the groundwater sampling?

Answer: No